

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241361  
Address: 3228 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:    | Outcome:          | Date:                      |
|-------------------------------------------------|---------------|-------------------|----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Shawn Hoffman | Ready for Temp CO | Friday, September 27, 2024 |

Corrective Action Required:

|   |      |                                                                                                                        |
|---|------|------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -sod<br>-splash blocks and sump pump discharge to extend 36" from foundation<br>-will check water meter at time of sod |
|---|------|------------------------------------------------------------------------------------------------------------------------|

**Comments:**