

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242079
Address: 1604 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, October 18, 2024

Corrective Action Required:

1	Misc	-install LGT2 at girder R1 -missing truss hangers per plans. Plans do not specify certain hangers identified in key -provide hold down device at stair landing -anchor bolts to be tight throughout -provide 3 studs at exterior wall corners in basement -ufer ground connection not properly installed
---	------	---

Comments: