

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20230570
Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Friday, October 18, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Ready for Temp CO	Friday, October 18, 2024

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Approval required from: Fire, Planning, FEI
-Provide compliance with NEC 110.16(B)
-Provide gfi protection for receptacles located within 6 ft of nourishment area sink
-Provide a clear floor space with minimum 30" width at urinal. Have architect address
-All receptacles less than 5.5 ft from floor located in business offices and corridors of medical facility are required to be tamper-resistant receptacles. NEC 496.12 (5)
-Provide verification of 1-hr fire rating of the roof access rm wall
-Secure rooftop unit LFNC raceways per code |
|---|------|--|

Comments:

