

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Shawn Hoffman	Partial	Thursday, October 17, 2024

Corrective Action Required:

1 Misc INSPECTED TRENCH AND CONDUIT

- A4.5: 1.3-1.6

Corrective Action Required:

2 Misc Approved to cover

- UE from transformer to CT cabinet and 29 out it cabinet ( South West corner)

- UE continue from out of CT cabinet to 1.7 then turn to A1 10/10/24

- 1.7: A2-A4

- A5: 1.4-1.6 AND ACROSS TO A2 10/15

Corrective Action Required:

3 Misc INSPECTED ELEVATOR CONDUIT OUT TO VARIOUS LOCATIONS

- SUMP

- FIRE

-ELECTRICAL

**Comments:**