

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241184
Address: 3208 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Monday, October 21, 2024

Corrective Action Required:

1	Misc	No further inspections until Erosion control on N side of lot addressed -sod -splash blocks and sump pump discharge to extend 36" from foundation -missing egress ladder for window well -will check water meter at time of sod (ensure meter well lid flush with grade and meter 14"-18" from top of meter to well lid ring) -address plot plan not matching as built
---	------	---

Comments: