

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243632
Address: 1538 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, October 22, 2024

Corrective Action Required:
2 Misc

- anchor bolts to be I. The middle 1/3 of sill plate. (See portal frame)
- block all sheathing breaks in garage
- address open electrical at front door
- address bath vents above primary bath
- provide blocking under kitchen island
- anchor all steel columns in basement

Comments: