

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242625
Address: 1633 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Tuesday, October 22, 2024

Corrective Action Required:

1	Misc	-uncover covered front porch -seal all penetrations into furr down -secure SE Cable within 12" of disconnect -fire block into furr down at powder room -fireblock pantry hvac chase into furr down -fire block kitchen wall into garage furr down (seal gaps) -seal hvac chase at kitchen/garage wall into furr down and ceiling space -fire block hvac chase at great room windows -solid block sheathing breaks 2nd floor -seal dead space at primary bath -Add stud where missing at 2nd floor hvac chase -nail exterior sheathing to code and plans
---	------	--

Comments: