

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235113

Address: 2740 NE HAGAN RD, Unit:A, LEES SUMMIT, MO 640642740 NE HAGAN RD, Unit:B, LEES SUMMIT,  
MO 640642740 NE HAGAN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Kyle Beard	Partial	Tuesday, October 22, 2024

Informational:

1	Misc	Building drain under hangar and GSE storage, to underground connection outside near interceptor-OK
---	------	--

Sanitary waste building drain at south side of building-OK

Rest of sanitary drain, except from line 2 to 4

Informational:

2	Miscellaneous Correction	All sanitary drain line is completed and is ok to cover
---	-----------------------------	---

Door track drains will be installed and called in for inspection at a later date

This is a partial pass only

**Comments:**