

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241067
Address: 2087 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Robb Popp	Passed	Wednesday, October 23, 2024

Informational:

1 Misc

-CSST secured in joist space less than 3" to bottom of joists requires 16g striker plate-EVERYWHERE CSST IS SECURED LESS THAN 3" TO BOTTOM OF JOIST PROTECTION IS REQUIRED

**Item moved to occupancy inspection notes

Comments: