

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Devon Perry	Passed	Wednesday, October 23, 2024

Informational:

1	Misc	10-18-24 DP. Floyds crew flushed the private 6" to the new fire hydrant today.
		10-21-24 DP. Met crew onsite to take the first sample on above listed water line today. Nick delivered it to Blue Valley Labs
		10-22-24 DP. Sample 1 passed

**Comments:**