

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242665
Address: 3804 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, October 23, 2024

Corrective Action Required:

2	Miscellaneous Correction	3804 SW Ravengate. All rough (4) Vertically support electrical wires to code between HVAC unit in basement at floor joist above unit (not completed) Walk your property before scheduling inspections
---	--------------------------	---

Comments: