

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232357

Address: 442 SW BRUMMEL RD, LEES SUMMIT, MO 64081444 SW BRUMMEL RD, LEES SUMMIT, MO
64081446 SW BRUMMEL RD, LEES SUMMIT, MO 64081448 SW BRUMMEL RD, LEES
SUMMIT, MO 64081440 SW BRUMMEL RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Shawn Hoffman	Failed	Wednesday, October 23, 2024

Corrective Action Required:

1	Misc	All units - Provide gutters and downspouts - Splash pads - Irrigation permit - Water meter at grade with meter 14-18" from lid and gravel in bottom - All water mains to have regulator installed
	446	- Basement Egress window damaged

Comments: