



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114694, Building Permit - Commercial

Address: 834 SW BLUE PKWY, LEES SUMMIT, MO 64063846 SW BLUE PKWY, LEES SUMMIT, MO 64063848 SW BLUE PKWY, LEES SUMMIT, MO 64063852 SW BLUE PKWY, LEES SUMMIT, MO 64063856 SW BLUE PKWY, LEES SUMMIT, MO 64063858 SW BLUE PKWY, LEES SUMMIT, MO 64063862 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Tuesday, October 25, 2011

Partial Correction  
2 MISC

GAS PIPING PRESSURE TEST HELD STEADY AT  $\geq 10$  PSI FOR  $\geq 10$  MIN. AT SERVICE PIPING TO FOLLOWING SPACES: 838; 840; 846; 848; 852; 856; 858; 862

Partial Correction  
3 MISC

PAINTING OF GAS PIPING IN PROGRESS

<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Tuesday, October 25, 2011
--	------------	--------	---------------------------

**Comments: RELEASE GAS SERVICE FOR SPACES 840; 848; 856**