

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240545  
Address: 3713 SW CLAYTON PL, LEES SUMMIT, MO 640823715 SW CLAYTON PL, LEES SUMMIT, MO  
640823717 SW CLAYTON PL, LEES SUMMIT, MO 640823711 SW CLAYTON PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Thursday, October 24, 2024

Corrective Action Required:

2	Miscellaneous Correction	3711 SW Clayton Occupancy (2)
		3711
		Nail missing in deck joist hanger
		Lower water meter lid to ground level
		3717
		Missing nail in deck joist hanger

**Comments:**