LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1303
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No: PRCOM20115779 Date: October 24, 2011

Project Title: Pfizer Applicant:

Location: 1 SE PFIZER WAY, Siemens Industry, Inc.

Occupancy Group: H
Description: Alarm System Replacement

Construction Type: Type IA Map Page: 195Q

Type of Work:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review Reviewed By: Jim Eden Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans recieved October 21, 2011.

2. Provide smoke detection over the FACP.

Verified at inspection.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule testing.

4. The fire suppression system for the hydrocarbon storage unit shall be monitored by the alarm system.

Verified at inspection.

5. Duct detection activation shall provide a supervisory signal only without activating the interior horn/strobes.

Verified at inspection.