

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Thursday, October 24, 2024

Corrective Action Required:

1 Misc

Pre final for units:

***Building A
4th floor

- Install accessible signage at elevator and stairwells
- Secure electrical at islands throughout
- Seal all floor and ceiling penetrations at mechanical rooms

- 1400-Missing spark rings at kitchen
- 1401-Missing AFCI at fridge
- 1402-Spark rings at kitchen
- 1403-Fire caulk line set at mech rm
- 1404-Spark rings at kitchen, receptacle at kitchen does not work, seal penetration at mech closet, adjust door to self close and latch

Comments: