

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOMCOM20240778  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 2</b>	Devon Perry	Partial	Thursday, October 24, 2024

Informational:	
1 Misc	10-23-24 DP. Met Floyd onsite and took the second sample for the private 6" line to the single fire hydrant
	10-24-24 DP. Second sample failed for TC. Will meet Floyd on Monday for a third sample.

**Comments:**