

CITY OF LEE'S SUMMIT CODES ADMINISTRATION

220 SE GREEN ST. P.O.BOX 1600 PHONE: 816-969-1200

FAX:

816-969-1201

TemporaryCertificate of Occupancy

Permit #: PRCOM20113275

Address: 691 NW BLUE PKWY, LEES SUMMIT, MO 64086

Inspected On: Tuesday, October 25, 2011
Inspected By: John BornsJoe Dir

Expiration Date: 11/10/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Borns Temporary C of O Tuesday, October 25,

Codes Commercial 2011

Corrective Action Required:

2 MISC VENT TERMINATION IN ELECT XFMR SERVICE YARD NOT

SECURED TO WALL; HOLE SAW DEBRIS LEFT BEHIND

Occupancy Inspection - Joe Dir Passed Tuesday, October 25,

Fire 2011

Comments: TCO EXTENDED TO 11/10/2011