

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242214
Address: 3816 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Friday, October 25, 2024

Corrective Action Required:

2	Miscellaneous Correction	3816 SW Ravengate. Occupancy (3)
		Sump pump extension is not installed Splash pads are not installed
		Pay 3rd consecutive inspection fee

Comments: