

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242079  
Address: 1604 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Friday, October 25, 2024

Corrective Action Required:

1	Misc	-install LGT2 at girder R1 -missing truss hangers per plans. Plans do not specify certain hangers identified in key -provide hold down device at stair landing -anchor bolts to be tight throughout ( remove insulation for inspection) -provide 3 studs at exterior wall corners in basement(remove insulation for inspection) -ufer ground connection not properly installed
---	------	---

Comments: