

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243018  
Address: 1905 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Monday, October 28, 2024

Corrective Action Required:

1	Miscellaneous Correction	1905 SW Hightown. Occupancy  Back porch steps riser height are not to code on 3/8 of an inch variance Fire block bottom of chases in garage Stair riser height from main living area to basement can not exceed 7 3/4 inches Lights in basement are not installed Secure electrical above HWT Sod, splash pads and sump pump extensions are not installed Seal all exterior penetrations
---	--------------------------	--

Comments: