

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241188

Address: 1456 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1454 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Failed	Monday, October 28, 2024

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	ABOVE CEILING and RIM BOARD  1454: -Close off gap at roof deck above garage; fire-caulk around penetrations of membrane (above master shower and at ridge; mud&tape seam above master bedroom -Extend 1-hr wall through soffit at front of garage  1456: -Close off hole in attic wall above master bathroom/bedroom corner; fire-caulk around penetrations of membrane at ridge -Extend 1-hr wall through soffit at front of garage
---	----------------------------------	--

Comments: