

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241618  
Address: 1801 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector: | Outcome: | Date:                     |
|-------------------------------------------------|------------|----------|---------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Kyle Beard | Failed   | Tuesday, October 29, 2024 |

Corrective Action Required:

|   |                          |                                                                                                                                                                                              |
|---|--------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Miscellaneous Correction | 1801 SW Hightown. Occupancy<br><br>No light receptacle at the bottom of the stairs to illuminate the stairs<br><br>House is locked and no access code was provided<br>KBEARD 10/29/24 9:05am |
|---|--------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Comments:**