

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240229
Address: 2116 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Ready for Temp CO	Tuesday, October 29, 2024

Corrective Action Required:

1	Misc	-Complete final grade, sod, splash blocks, foundation drainage -Secure ac whip within 12" of box
---	------	---

Comments: