

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241047

Address: 1450 SW WINTHROP TER, LEES SUMMIT, MO 64081
1448 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, October 29, 2024

Corrective Action Required:

1	Misc	1448
		- Tighten anchor bolts at garage portal frame
		- Gas service not bonded
		- UFER ground to be at first point of disconnect (remove conductor from sub panel to UFER)
		1450
		ok

Comments: