

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242625
Address: 1633 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, October 29, 2024

Corrective Action Required:

1	Misc	-seal all penetrations into furr down in garage -secure SE Cable within 12" of disconnect -seal hvac chase at kitchen/garage wall into furr down and ceiling space
---	------	--

Comments: