

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242193  
Address: 2123 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Tuesday, October 29, 2024

Corrective Action Required:

1	Misc	10-28-24 Dustin A, Dw has standing water in it. Cannot pour , must recall when water is gone and dried out . FAILED.
		10-29-24 Dustin A, Water has been removed and recompactd. Approved to pour

**Comments:**