

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20243945

Address: 5008 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064  
5004 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Tuesday, October 29, 2024

Corrective Action Required:

1	Misc	-Fire approval required
		-Receptacles located within 6 ft of the kitchen sink shall be gfci-protected

**Comments:**