

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241188
Address: 1456 SW WINTHROP TER, LEES SUMMIT, MO 640811454 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, October 30, 2024

Corrective Action Required:

1	Misc	1454: -Staple north basement closet light wiring min 1.25" from nailing surface -Protect plumbing at basement bathroom bottom&top wall plates with BOCA plates **protect the PVC at bottom wall plate per code -Seal gap and penetration of joist return air space above basement bathroom wall 1456: -Identify feeder EGC and grounded conductors inside panel with proper color; isolate grounded bus bar from equipment grounding bus bar **Tape the feeder EGC with green tape. Yellow tripe is not a proper identifier for EGC; remove the bar that connects the EGC bus bar and the neutral bus bar
---	------	---

**OK TO INSULATE

Comments: