CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241188

Address: 1456 SW WINTHROP TER, LEES SUMMIT, MO 640811454 SW WINTHROP TER, LEES SUMMIT, MO

64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Rated Assembly Inspection Khanh Nguyen Partial Wednesday, October

30, 2024

Informational:

1 THE FOLLOWING ABOVE CEILING and RIM BOARD ONLY:

AREAS ARE 1454:

APPROVED -Extend 1-hr wall through soffit at front of garage

1456:

-Extend 1-hr wall through soffit at front of garage

DWELLING SEPARATION:

Comments: