

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241047

Address: 1450 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1448 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, October 30, 2024

Corrective Action Required:

1	Misc	1448-Gas test approved
		1450: -Install gauge and provide min 20 psi test pressure

**Comments:**