

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20242655
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	Robb Popp	Failed	Wednesday, October 30, 2024

Corrective Action Required:

1	Misc	-1 Hour call ahead was requested. Called at 9:05 am. 10:20 am no contractor on site. Opened one light pole hand hole and copper ground wire not connected. -Complete work per plan and schedule when contractor will be on site with light poles opened for inspection
---	------	---

Comments: