CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20241045 Address: 1433 SW WINTHROP TER, LEES SUMMIT, MO 640811431 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Failed	Wednesday, October 30, 2024
Corrective Action Required:			
1 Misc	ATTIC AND RIM ARE APPROVED		
	- PLANS CALL FOR 7" O.C. FIELD AND EDGE, FILL IN LOCATIONS THROUGHOUT		
	WERE SCREWS EXCEED	THE MINIMUM	

Comments: