



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115780, Building Permit - Commercial  
Address: 44 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	Mike Copeland	Passed	Wednesday, October 26, 2011

<b>Final Plumbing Inspection - Commercial</b>	Mike Copeland	Passed	Wednesday, October 26, 2011
---	---------------	--------	-----------------------------

Corrective Action Required  
1 MISC

**Comments:**