

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244806  
Address: 261 SE COYLE DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Khanh Nguyen	Passed	Wednesday, October 30, 2024

Informational:  
1 Misc

Bonded:  
-perimeter, handrail, pool metal framing, ladder, jumper to equipment location, pool water inside skimmer

**Comments:**