

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232358

Address: 452 SW BRUMMEL RD, LEES SUMMIT, MO 64081454 SW BRUMMEL RD, LEES SUMMIT, MO  
64081456 SW BRUMMEL RD, LEES SUMMIT, MO 64081458 SW BRUMMEL RD, LEES  
SUMMIT, MO 64081450 SW BRUMMEL RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Shawn Hoffman	Failed	Wednesday, October 30, 2024

Corrective Action Required:

1	Misc	All units - Provide Splash pads  - All water mains to have regulator installed after fire sprinkler line
---	------	---

Shawn Hoffman 10/30/2024 1:37 PM  
incorrect instalation of regulators

**Comments:**