

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Devon Perry	Partial	Wednesday, October 30, 2024

Informational:

1	Misc	10-29-24 DP. Met Floyd onsite and took sample 3 from the 6" fire hydrant line, sample 1 from the domestic service line and the fire line to the building pad.
		10-30-24 DP. The 3rd sample from 3 from the 6" fire hydrant line, sample 1 from the domestic service line and the fire line to the building pad all PASSED

Comments: