CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOMCOM20240778 Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Water Line - Coliform Test 2	Devon Perry	Partial	Wednesday, October 30, 2024	
Informational:				
1 Misc	10-23-24 DP. Met Floyd onsite and took the second sample for the private 6" line to the single fire hydrant10-24-24 DP. Second sample failed for TC. Will meet Floyd on Monday for a third sample.			
	from the 6" private fire hy	0-30-24 DP. Met Marty onsite with She Digs it and pulled second samples rom the 6" private fire hydrant line and also the domestic service line and ire line to the building pad today. All three samples were delivered to Blue 'alley Labs.		

Comments: