CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20241886 Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Site Visit		Devon Perry	Partial	Wednesday, October 30, 2024
Informati	onal:			
1		-30-24 DP. Advanced Excavation is onsite and is just grading the site. They d to removed a wet spot around a manhole that was backfilled by sap with rge chunks of asphalt. That was all removed and dirt was properly installed ck with a third party tester onsite performing compaction testing.		

Comments: