

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20231337

Address: 940 NE COLBERN RD, LEES SUMMIT, MO 64064900 NE COLBERN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Nick Scott	Partial	Thursday, October 31, 2024

Informational:

1	Misc	12-18-23 NS Site Visited and no erosion control issues 12-22-23 NS Site Visited and no erosion control issues 1-3-24 NS Site Visited and no erosion control issues 1-23-24 NS Site Visited and no erosion control issues 3-29-24 NS Site Visited and no erosion control issues 4-18-24 NS Site Visited and no erosion control issues 6-28-24 NS Site Visited and no erosion control issues 7-25-24 NS Site Visited and no erosion control issues 8-8-24 NS Site Visited and no erosion issues 8-22-24 NS Site Visited and no erosion issues 9-30-24 NS Site Visited and no erosion control issues 10-14-24 NS Silt fence needs to be put back up and repaired around job site with grass seed put down with gutter buddies in every storm inlet. 10-31-24 NS Site Visited and no work has been done since last inspection.
---	------	--

Comments: