

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242156
Address: 2760 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, October 31, 2024

Corrective Action Required:
3 Misc

- Provide anchor bolts at steel column garage/ entry wall
- Fire block top of HVAC chase in garage
- Fire block top of double wall in kitchen to prevent transfer our fire and gases into joists space
- Fire block top of chase in dining room
- Fire block top of both chases in great room
- Has piping not installed
- Anchor steel columns in basement
- Not a complete list, will resume after piping installed

Comments: