

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242943
Address: 2778 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Not Ready	Thursday, October 31, 2024

Corrective Action Required:

1	Misc	- -MIN (2) 1/2" DIA. ANCHOR BOLTS INSTALLED PER plan at garage portal frame - -R403.1.6 W/ 2"x2"x3/16" PLATE WASHER - -ANCHOR BLTS TO BE IN MIDDLE THIRD OF SILL PLATE - - STRAPS TO BE 2000 LB STRAPS at portal frame - - remove soffit vent at garage eye brow - Fire block basement wall at stairs vertically every 10'
---	------	---

Corrective Action Required:

2	Misc	NO CHANGE Shawn Hoffman 10/31/2024 10:37 AM house insulated without all rough approved
---	------	--

Comments: