

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232357

Address: 442 SW BRUMMEL RD, LEES SUMMIT, MO 64081444 SW BRUMMEL RD, LEES SUMMIT, MO
64081446 SW BRUMMEL RD, LEES SUMMIT, MO 64081448 SW BRUMMEL RD, LEES
SUMMIT, MO 64081440 SW BRUMMEL RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Devon Perry	Passed	Thursday, October 31, 2024

Corrective Action Required:

1	Miscellaneous Correction	Building 3 punch list: For TCO- Fix issues with water meters For Final- Fix cracks in curbs and replace curb in front of ADA ramp. Extend blind indicator the width of the curb. 10-31-24 DP. All punch list items for building 3 have been completed. The repairs to the curb will be transferred to PRSITE20224130
---	--------------------------	---

Comments: