

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232358

Address: 452 SW BRUMMEL RD, LEES SUMMIT, MO 64081454 SW BRUMMEL RD, LEES SUMMIT, MO  
64081456 SW BRUMMEL RD, LEES SUMMIT, MO 64081458 SW BRUMMEL RD, LEES  
SUMMIT, MO 64081450 SW BRUMMEL RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Devon Perry	Temporary C of O	Wednesday, October 30, 2024

Corrective Action Required:

1	Miscellaneous Correction	10-24-24 DP. Building 4 punch list:  -Need to fix list for water meter issues -Fix broken curb, especially in front of ADA ramp -Extend indicator pad at ADA the width of the opening.
---	--------------------------	--

10-30-24 DP. Water meters issues have been repaired. TCO Granted.  
Still need to fix site related work before receiving C/O

**Comments:**