

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234858  
Address: 2147 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Friday, November 01, 2024

Corrective Action Required:

1	Misc	-Secure AC whips within 12" -Connect whip to AC unit -Provide GFCI/AFCI protection at wall receptacle in laundry -Provide AFCI protection at fridge and washer -Install sliding glass door hardware -Label non GFCI receptacles -Anchor column base in mechanical room -Obtain lawn irrigation permit and backflow certification
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: