

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241620
Address: 1809 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Friday, November 01, 2024

Corrective Action Required:

1	Miscellaneous Correction	First to second stair riser going to the basement has a greater than the code 3/8 of an inch difference allowance Basement stair platform does not have the code 36 inches of travel distance Bottom basement stairwell does not have a light switch for proper illumination Pay \$75 fee associated with this permit
---	--------------------------	--

Comments: