## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## Temporary Certificate of Occupancy

Permit #: PRRES20241680

Address: 3220 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

Inspected On: Friday, November 01, 2024

**Inspected By:** Development Center

**Expiration Date:** 

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Friday, November 01,

Residential

Corrective Action Required:

1 Misc -Final grade and sod

-uncover covered water meter

-splash blocks and sump pump discharge to extend 36" from foundation

2024

-guard rail at front stoop where greater than 30" from grade 36" out.

**Comments:**