

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232699
Address: 1201 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, November 04, 2024

Corrective Action Required:

2	Misc	- Issues with smoke detectors in upstairs hall and bedroom 3 - cover open j box basement above electrical panel - Label non GFCI at electrical panel - Provide lid for attic of single car garage - Add retaining wall to plot plan
---	------	---

Comments: