

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241487
Address: 3241 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, November 04, 2024

Corrective Action Required:

1	Misc	No pressure at gas gauge
		No address posted inspection denied
		Fire place not installed gas line capped no shut off at fireplace
		DONT CALL FOR INSPECTION UNTIL READY. NOT READY FEE ASSESSED.

Comments: