

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242566
Address: 3117 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, November 04, 2024

Corrective Action Required:

1 Misc

- missing stud at small wall between garage doors
- missing plate under header at cspf rear wall both corners(installed incorrectly, plate to be above jack studs)
- front entry wall top plate not tied together with adjoining exterior walls
- security blocking for front door
- missing truss lateral bracing multiple trusses throughout

Comments: